



**STANDARD SPECIFICATIONS
AND
CONSTRUCTION DETAILS**

**NORTH COAST COUNTY WATER DISTRICT
2400 Francisco Boulevard, Post Office Box 1039
Pacifica, California 94044
NOVEMBER 2006**



CURRENT EDITION. You must use the most current edition of the *Standard Specifications and Construction Details* available. Please call (650) 355-3462 to verify the date of the most current edition.

ADDENDUMS. Periodic addendums will be made available at no charge.

UPDATES. *Standard Specifications and Construction Details* will be updated approximately every 2 years. Updated editions must be purchased.

TABLE OF CONTENTS

| SECTION 1 | Materials of Construction | Page |
|---|---|-------------|
| 1. | General | 1 |
| 2. | Pipe | 1 |
| 3. | Fittings | 1 |
| 4. | Joints | 2 |
| 5. | Valves | 3 |
| 6. | Polyethylene Wrap | 3 |
| 7. | Fire Hydrants | 3 |
| 8. | Boxes | 4 |
| 9. | Pressure Reducing Station | 4 |
| 10. | Threaded Parts | 4 |
| SECTION 2 Domestic Water Pipeline Construction | | |
| 1. | General | 5 |
| 2. | Excavation | 6 |
| 3. | Backfill | 7 |
| 4. | Pipe Installation | 8 |
| 5. | Hydrostatic Testing | 11 |
| 6. | Flushing and Chlorinating | 13 |
| 7. | Repaving | 14 |
| 8. | Backfill Outside of Travelway | 14 |
| Exhibit A – Criteria for the Separation of Water Mains and Sanitary Sewers | | |
| Standard Construction Details | | |
| | Residential Service Connection (New Construction) | NC-01 |
| | Residential Service with Fire Service Upgrade | NC-02 |
| | Standard Service Saddle Requirements | NC-03 |
| | Standard Service Reconnection | NC-04 |
| | Double Detector Check Backflow Unit for a Fire Service Connection | NC-05 |
| | ¾" – 2" Reduced Pressure Backflow Preventer | NC-06 |
| | Standard Underground PRV Vault | NC-07 |
| | 4 x 2 Pressure Reducing Station Inlet Pressures of 250 psi or Less | NC-08 |
| | 6 x 4 x 2 Pressure Reducing Station | NC-09 |
| | 8 x 4 Pressure Reducing Station | NC-10 |
| | 2" Blowoff Assembly | NC-11 |
| | Transmission Line Blowoff Assembly | NC-12 |
| | 2" Combination Air Release / Vacuum Valve (within improved/unimproved areas) | NC-13A |
| | 2" Combination Air Release / Vacuum Valve (within improved areas) | NC-13B |
| | Sample Station | NC-14 |
| | Standard Fire Hydrant with Check Valve Assembly Installation | NC-15A |
| | Standard Fire Hydrant Installation (Existing Hydrants Only) | NC-15B |
| | Fire Hydrant Guard Posts (4 Post Configuration)(in commercial/unimproved areas) | NC-16 |
| | Installation of Portable Water Meters | NC-17 |
| | Water Valve Box - Traffic | NC-18 |
| | Gate Valve Assembly / Tracer Wire Detail | NC-19 |
| | Standard Thrust Block Details | NC-20 |
| | Standard Pipe Installation | NC-21 |
| | Typical Service Installation Trench | NC-22 |
| | Separation of Water Mains & Sanitary Sewers | NC-23 |
| | Typical Private Atmospheric Vacuum Breaker (Industry Standard Installation) | |

Standard Construction Details (continued)

City of Pacifica Standard Trench Detail Notes
City of Pacifica Standard Trench Detail (Dwg 301)
City of Pacifica Standard Trench Detail (Dwg 301A)
City of Pacifica Slurry Seal Detail (A) (Plan No. 301 B)
City of Pacifica Slurry Seal Detail (B) (Plan No. 301 C)
City of Pacifica Slurry Seal Detail (Longitudinal) (Plan No. 301 D)
City of Pacifica Slurry Seal Detail (No Center Line) (Plan No. 301 E)
City of San Bruno Typical Trench Cross Section